



CIEMAT office building



Introduzione

This public building hosts the headquarters of the Renewable Energies Division of Ciemat. It was built in two stages between the years 1970-1980, and some decades after has suffered from a series of quite serious structural problems. This led to undertake an integral rehabilitation. Once solved the stability problems, rehabilitation of the roof was then undertaken, later the façades, and finally the interior spaces. The BIPV system was integrated in the new ventilated façades. Arch. Juan Carlos Gutiérrez (Architecture & Project Unit of Ciemat) met the PV researchers involved and the PV installer company Ehiso several times before the final project. The installer was responsible for the administrative formalities to legalize and register the photovoltaic system, a process that concluded in July 2015. The installation was legalized by the body in charge of the electrical installations in the Autonomous Community of Madrid.

Source: [Successful Building Integration of Photovoltaics – A Collection of International Projects](#)

Integrazione estetica

The BIPV system is integrated into the ventilated façade of the three-story building. The building is located at the Ciudad Universitaria Campus in Madrid, and it is visible from the access road and the main avenue. The PV modules are combined with the polymer concrete panels used on the façades, achieving a good integration from an aesthetic point of view thanks to the similarity of colors and shapes. However, the integration has not sought to conceal the photovoltaic modules; rather it has been considered that making them visible has a positive effect and provides a modern, exemplary image. (Arch. Juan Carlos Gutiérrez, Architecture & Project Unit of Ciemat)

Integrazione energetica

The rated energy of the BIPV system is 20 MWh/year. The PV modules are distributed over the south, east and west facades, to achieve a flatter generation curve throughout the day, contributing to feed the building's baseline load along the year. All the energy generated is instantaneously self-consumed in the building, which means a self-consumption index of 100%.

Integrazione tecnologica

The BIPV system is made of large standard high efficiency PV modules, made of glass/EVA/PV cells/EVA/white PVF. The PV modules (SunPower E18-305W and E20-327W) form part of two photovoltaic installations: one of 27.2 kWp connected to the building's local electric power grid, and another stand-alone of 4.8 kWp. They occupy a total surface area of about 172.9 m², replacing conventional construction elements on the upper areas of the east, south and west façades. They are back ventilated (not tight air chamber of about 100 mm). The east façade PV system is divided into three sub-systems to reduce losses due to partial shading caused by nearby trees. The PV modules are fixed to a galvanized steel support structure, in parallel to that of the rest of the façade.

The PV system was provided with the “zero injection” device that prevents PV energy from being dispatched to the electric power grid outside the building, in compliance with the Spanish legislation at the time of the renovation. The device monitors the electrical network and photovoltaic inverters at all times to modulate photovoltaic production in relation to electrical consumption in order not to send

energy to the grid. (Javier Pérez, PV installer)

Processo decisionale

The decision of integrating PV into the building façade was led by the architect of the center, Juan Carlos Gutiérrez, in charge of the rehabilitation project, and supported by the General Director of CIEMAT, the Director of the Renewable Energies Division and the Photovoltaic Unit. The building had to be retrofitted after the technical municipal inspection, and the ventilated façade for the outer envelope of the building appeared as the most suitable option. The retrofit building would become a showcase of the inside i+D activities and, at the same time, demonstrate one easy to reproduce BIPV solution.

The type of material for the ventilated façade was defined on the basis of the PV modules' characteristics, seeking a product that would allow for similar dimensions, such that someday, if necessary, the PV panels could be interchanged without detracting from the general appearance of the whole of the façade, and adapting the modulation and the general appearance to these elements such that the integration would be as effective as possible. (Arch. Juan Carlos Gutiérrez - Architecture & Project Unit of Ciemat)

Lessons learnt

There are no subsidies or economic incentives, but the installation saves energy consumption from the grid: it is a 100 % self-consumption case. The total cost of the installation, including maintenance and reposition of the PV inverters (once in 30 years), is 2.7 €/Wp. Discounting the cost saved in conventional façade, the net cost of the BIPV installation becomes 1.84 €/Wp.

This is an example of a non-expensive, easy- to-implement good architectural solution for building retrofit with standard PV modules integrated in a new ventilated façade. The effect of shadowing caused by the nearby trees may be significant, so if not possible to avoid, at least divide the system in different parts to reduce energy losses.

DATI EDIFICIO

Tipologia progetto	riqualificazione
Destinazione d'uso	uffici
Indirizzo edificio	Avda. Complutense 40, Madrid, Spagna

Sistemi BIPV

DATI SISTEMA BIPV

Sistema architettonico	facciata ventilata
Anno integrazione BIPV	2015
Active material	silicio monocristallino
Trasparenza modulo	opaco
Tecnologia modulo	vetro-backsheet, FV riconoscibile, moduli standard
Potenza sistema [kWp]	32
Area sistema [m²]	172,9
Dimensioni modulo [mm]	1046 x 1559
Orientamento moduli	est, sud, ovest
Inclinazione moduli [°]	90
Produzione FV annuale [kWh]	20000

COSTI SISTEMA BIPV

Costo totale [€]	58880
€/m²	340
€/kWp	1840

Stakeholders

Progettista principale

Arch. Juan Carlos Gutiérrez (Architecture & Project Unit of Ciemat)

Installatore sistema BIPV

Ehiso Energía S.L. (closed)

-
-
-

Produttore componenti BIPV

SunPower

51 Rio Robles San Jose, California, USA

1-408-240-5500

<https://us.sunpower.com/>



CIEMAT office with project team © CIEMAT



CIEMAT office with the access road © CIEMAT



Renovation work details. PV modules mounting © CIEMAT



Supporting structure and fixation details © CIEMAT



Renovation work finished © CIEMAT

Autore caso studio:

Nuria Martín Chivelet (CIEMAT, Renewable Energy Division)